

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM



LISTING SERVICE

LISTING No. 8110-2064:0500 Page 1 of 1

CATEGORY: 8110 -- DECKING FOR WILDLAND URBAN INTERFACE (W.U.I.)

LISTEE: Nusku Partners LLC 4501 Brickell Privado Street, Ontario, CA 91761
Contact: Tim Hummel (909) 591-4841 Fax (909) 591-4818
Email: tim@wehardenhomes.com

DESIGN: Thermally Modified Ash Nusku Thermacor Decking, material nominal 5/4" x 6" with a 3/16" maximum edge to edge spacing.

Refer to the manufacturer's installation instructions and product data sheets.

RATING: SFM 12-7A-4A

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes and ordinances, and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model number, rating, and SFM label.

APPROVAL: Listed as decking materials for use in the Wildland Urban Interface areas when attached exterior wall covering is also composed of noncombustible or ignition-resistant material. Refer to listee's Installation Instruction Manual for details.

NOTE: Test Protocol SFM 12-7A-4A

04-24-20 VWW



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other

Date Issued: **July 01, 2020**

Listing Expires **June 30, 2021**

Authorized By: **DAVID CASTILLO, M.E., F.P.E.**
Fire Engineering Division